#### SECTION 07 92 00 - JOINT SEALANTS

### PART 1 - GENERAL

- 1.1 EXTENDED WARRANTY: Provide a written two-year warranty, signed by Contractor and sealant installer, guaranteeing all exterior joints and interior joints detailed within the Vivarium to be water and air tight for a period of not less than two (2) years from date of the Letter of Acceptance of the Work by the University.
  - 1. Exception: Provide 20 year warranty period from date of the Letter of Acceptance of the Work by the University for sealants used in BSL3 only.

# PART 2 - PRODUCTS

# 2.1 JOINT SEALANTS

- A. Single-Component, Nonsag, Neutral-Curing Silicone Joint Sealant: ASTM C 920, Type S, Grade NS, Class 100/50, for Use NT.
  - 1. Use: For joints in vertical surfaces.
  - 2. Products: Subject to compliance with requirements, provide one of the following:
    - a. Dow Corning Corporation; 790.
    - b. GE Advanced Materials Silicones; SilPruf LM SCS2700.
    - c. Tremco Incorporated; Spectrem 1.
- B. Single-Component, Pourable, Traffic-Grade, Neutral-Curing Silicone Joint Sealant: ASTM C 920, Type S, Grade P, Class 100/50, for Use T.
  - 1. Use: For joints in horizontal traffic surfaces.
  - 2. Products: Subject to compliance with requirements, provide one of the following:
    - a. Dow Corning Corporation; 890-SL.
    - b. Pecora Corporation: 300 SL.
    - c. Tremco Incorporated; Spectrem 900 SL.
- C. Mildew-Resistant, Single-Component, Acid-Curing Silicone Joint Sealant: ASTM C 920, Type S, Grade NS, Class 25, for Use NT.
  - 1. Use: For joints in restrooms, janitor's closets, and other areas subject to continued moisture exposure or high humidity, including door frames and all static joints in ABSL and animal facilities.
  - 2. Products: Subject to compliance with requirements, provide one of the following:
    - a. BASF Building Systems; Omniplus.
    - b. Dow Corning Corporation; 786 Mildew Resistant.
    - c. GE Advanced Materials Silicones; Sanitary SCS1700.
    - d. Tremco Incorporated; Tremsil 200 Sanitary.
- D. Latex Joint Sealant: Acrylic latex or siliconized acrylic latex, ASTM C 834, Type OP, Grade NF.
  - 1. Use: For interior door frames and other static joints.
  - 2. Products: Subject to compliance with requirements, provide one of the following:
    - a. BASF Building Systems; Sonolac.
    - b. Bostik, Inc.; Chem-Calk 600.
    - c. Pecora Corporation; AC-20+.
    - d. Tremco Incorporated; Tremflex 834.
- E. Acoustical Joint Sealant: Nonsag, paintable, nonstaining latex.
  - 1. Products: Subject to compliance with requirements, provide one of the following:
    - a. Pecora Corporation; AC-20 FTR.
    - b. USG Corporation; SHEETROCK Acoustical Sealant.

JOINT SEALANTS 07 92 00 - 1

F. Cylindrical Joint-Sealant Backing: ASTM C 1330, Type C (closed-cell material with a surface skin), and of size and density to control sealant depth and otherwise contribute to producing optimum sealant performance.

# PART 3 - EXECUTION

# 3.1 INSTALLATION

- A. SPECIAL INSTALLATION REQUIREMENTS AT VIVARIUM AND CORE LAB: Provide the following for the Vivarium complete and the BSL3 Core Lab. Provide mildew-resistant sealant listed above at all conditions listed below:
  - 1. Ceilings: Fully seal all joints at access panels, light fixtures, electrical devices, mechanical devices, fire protection devices, etc.
  - 2. Walls: Fully seal all joints, including but not limited to, joints between finished wall surface and door and window frames, power boxes, plug mold, wire mold, alarm and sensor boxes, access panels, electrical devices, plumbing devices, mechanical devices, fire protection devices, wall bumper mounting plates, wall plates, wall-mounted equipment, window sills and jambs, etc.
  - 3. Wall and Ceiling Penetrations: Completely seal all penetrations, including but not limited to, joints between finished surface and electrical conduits, electrical plugs and switches, light fixtures, cover plates, piping for water, gas, vacuum, gas, soil and waste lines, mechanical ducts, registers, etc.
  - 4. Sealant is not required at inside corners of wall-to-wall and wall-to-ceiling joints in drywall construction or as a filler in preformed metal control and expansion joints in drywall construction.

# END OF SECTION 07 92 00

JOINT SEALANTS 07 92 00 - 2