

## **SECTION 08 00 00 - OPENINGS**

### PART 1 - GENERAL

#### 1.1 SYSTEM REQUIREMENTS

##### A. Design Requirements:

1. Design doors to be larger than the width of the largest piece of equipment to be installed in the space.
2. Provide either hollow metal or glazed aluminum storefront for all exterior doors; wood doors not permitted.
3. Provide either hollow metal or solid-core wood for interior doors.
4. Provide 3'-0" by 7'-0" doors typical; wider doors are permitted if required by function and approved by the University Project Manager.
5. Prepare doors and frames to receive security hardware including door switch monitoring devices. Refer to 28 13 00 – Access Control.
6. All replacement windows must be approved by the University Campus Architect and the University Project Manager.
7. Provide solid doors for vermin control at all OLAR doors.
8. All-glass doors are prohibited for interior use. Provide wood stile and rail doors with glass.

### PART 2 - PRODUCTS

#### 2.1 MATERIALS

##### A. Doors:

1. Provide all fire-rated doors and frames with an approved UL label.

### PART 3 - EXECUTION (Not Applicable)

**END OF SECTION 08 00 00**