

SECTION 09 65 00 - RESILIENT FLOORING

PART 1 - GENERAL (Not Applicable)

PART 2 - PRODUCTS

2.1 RESILIENT BASE AND ACCESSORIES

A. Resilient Base:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. Johnsonite.
 - b. Musson, R.C. Rubber Co.
 - c. Roppe Corporation, USA.
2. Material Requirement: Rubber.
3. Style: Cove at all locations.
4. Minimum Thickness: 0.125 inch.
5. Height: 4 inches.
6. Lengths: Coils in manufacturer's standard lengths.
7. Outside Corners: Preformed.
8. Inside Corners: Preformed.

B. Resilient Molding Accessory: Rubber.

1. Edge Strips: 0.125 inch thick, 1 inch wide, with tapered or bullnose edge.

C. Abrasive Strips: Self-adhesive, 1 inch wide, with aluminum oxide grit.

2.2 RESILIENT TILE

A. Vinyl Composition Floor Tile:

1. Class: Through pattern.
2. Wearing Surface: Smooth.
3. Thickness: 0.125 inch.
4. Size: 12 by 12 inches.

2.3 RESILIENT SHEET FLOORING

A. Vinyl Sheet Floor Covering: ASTM F 1303, Type I, Grade 1, with Class B backing.

1. Thickness: 0.080 inch thick.
2. Wearing Surface: Smooth.
3. Sheet Width: As standard with manufacturer.
1. Seaming Method: Heat welded at medical labs (BSL2); standard otherwise.

B. Linoleum Floor Coverings:

1. Sheet Flooring: In manufacturer's standard length by not less than 78 inches wide.
2. Seaming Method: Heat welded at medical labs (BSL2); standard otherwise.
3. Thickness: 0.08 inch.

2.4 INSTALLATION MATERIALS

1. Trowelable Leveling and Patching Compounds: Latex-modified, portland cement based provided or approved by manufacturer for applications indicated and capable of taper to feather edge.
2. Adhesives: Water-resistant type recommended by manufacturer to suit resilient products and substrate conditions indicated.

3. Floor Polish: Provide stripper, sealer and polish recommended by the University Environmental Health and Safety (EHS) through the University Project Manager.

PART 3 - EXECUTION

3.1 CLEANING AND PROTECTION

- A. Floor Polish: Strip factory seal and apply finish recommended by the University EHS through the University Project Manager.

END OF SECTION 09 65 00