

August 18 2020


CU Anschutz Campus-Wide Wayfinding Signs

Project Number: 19-182047

Addendum 4

Clarification of reference photos in Addendum 3.

The side inset/reveal shown in the piano hinge reference photos should not be included on the new signage. The new signage should have a flat side, and 1" reveal around the top and bottom of the sign as shown in the 100% Construction Documents and Campus Sign Standards and noted below.



1 Sign Type B: Illuminated Intent - Isometric View  
- Scale: NTS

Michael Stout