



# University of Colorado

Denver | Anschutz Medical Campus

## FIRE & LIFE SAFETY

1945 N. Wheeling St. (Campus Box F-410)  
Aurora, Colorado 80045  
303 724-3596

## Fire Alarm Reports April 2026

### Anschutz Medical Campus

Day / Date / Time	Location	Disposition
-------------------	----------	-------------

### Denver Campus (LS Center, SOB, City Heights, Lynx Xing and CU Building /Annex)

Day / Date / Time	Location	Disposition
Sat. 4/11 @ 14:40	City Heights/RH-1	False/Unknown.
Fri. 4/17 @ 05:30	City Heights/RH-1	Smoke alarm near Rm 6100 no fire or smoke found. <b>FA.</b>
Wed. 4/29 @ 12:30	City Heights/RH-1	Smoke alarm Rm 5111 no fire or smoke found. <b>FA.</b>

## TOTAL ALARMS FOR MONTH

An alarm followed by "FA" signifies a FALSE ALARM. An alarm followed by "NO FD" signifies no fire department response. Not initiating a response or cancellation of fire responders (after they have been called to respond) has been accepted, in writing, by the Aurora Fire Department. Our approved policy has specific guidelines that are to be followed prior to cancellation, and it is put into effect only when Facilities Management staff or University Police personnel arrive quickly and determine that the alarm is not an actual fire and that no hazard exists.

### Year-to-date

Anschutz Medical Campus:	7
Denver Campus:	5
<b>ALARMS TOTAL:</b>	<b>12</b>
FIRES WITH PROPERTY LOSS: (University loss above \$100.00)	1 (Denver Campus-March)
FIRE-RELATED INJURIES:	0

This document only applies to buildings owned and operated by the University of Colorado Denver. Please note that University of Colorado Hospital is a separately governed, non-profit entity, and the Auraria campus is managed and maintained by the Auraria Higher Education Center (AHEC). We have no information regarding fire alarms or fire-related incidents in non-CU owned locations or for any leased property.